

NIELSEN DILLINGHAM BUILDERS INC.

JOB HAZARD ANALYSIS

JOB HAZARD ANALYSIS		Date: 12-13-99
Contract:(If Applicable)		Phase: Concrete chipping
LLNL Group/Contractor/ Subcontractor/Subtier: Nielsen Dillingham Builders Inc.		Location: LLNL
NIF Element: CSP 4,5,6/10		
ACTIVITY OPERATIONS	UNSAFE CONDITION, ACTION or OTHER HAZARD	PREVENTATIVE or CORRECTIVE ACTION THAT WILL BE TAKEN
Chipping Concrete	Object in eye(s)	Wear safety glasses & face shield, keep others away from chipping operations.
"	Dust in lungs	Wear particulate dust mask.
"	Dust on skin	Wear long sleeve shirt. Wash Skin as often as necessary. Wear gloves.
"	Foot injury	Wear metatarsal foot protection.
"	Hearing damage	Wear ear protection if noise is > 85 dB.
	Struck by pneumatic air hose	Ensure that all air hose connec are equipped with whip checks or have connections wired in place to prevent accidental disconnection
	Electrocution	Check electrical hand tools and extension cords for damage. Replace or repair as needed
"	Injury to others	Keep others away from chipping activities with exclusion zone.

CM Concurrence

LLNL Group/Contractor/Subcontractor Concurrence

Subtier Concurrence