

**FORM S+H 5-1 JOB HAZARD ANALYSIS**

<b>JOB HAZARD ANALYSIS</b>		Date: 12/13/99
Contract:(If Applicable)		Phase: <b>Painting</b>
Contractor/ Subcontractor/Subtier: Nielsen Dillingham Builders Inc./		Location: LLNL-NIF
NIF Element: CSP- 6/10		
ACTIVITY OPERATIONS	UNSAFE CONDITION, ACTION or OTHER HAZARD	PREVENTATIVE or CORRECTIVE ACTION THAT WILL BE TAKEN
Painting	Inhalation of paint, lung damage.	Wear a respirator such as recommended on the MSDS.
"	Confined area without adequate ventilation.	Wear respirator that will protect for these conditions such as S.A.R. or P.A.P.R. or provide proper ventilation.
"	Skin irritation	Wear long-sleeved, loose fitting clothing that covers all exposed skin.
"	"	Wash exposed areas thoroughly with soap and water after handling.
"	"	Do not wash skin or hands with paint thinner or lacquer thinner, use hand cleaner.
"	Skin irritation to hands	Wear gloves that are impervious to paint and thinners.
"	Contamination of clothing	Wash work clothes separately from other clothing; rinse washer after thoroughly after use .
"	Eye irritation	Wear goggles that seal eyes from paint.
"	Fire	Properly store paints that may be combustible.
"	"	Properly dispose of dirty rags into airtight containers.
"	"	No smoking allowed in or around painting area or paint storage area.
"	"	Promptly clean up spills and leaks.
"	"	Keep combustibles away from ignition sources.
"	"	Keep fire extinguisher near painting operations.

\_\_\_\_\_  
CM Concurrence

\_\_\_\_\_  
LLNL Group/Contractor/Subcontractor Review

\_\_\_\_\_  
Subtier Review